

EXISTING FACILITIES

Hawkins-Whitby Fema Community Safe Room - 1101 WILLIAMSON ST, Milan, TN

APPROACH & ENTRANCE

ENTRANCE

The inaccessible entrances do not have directional signs to the accessible.



The mechanism that unlocks the locked doors from the inside requires more than the maximum 5lbs of pressure.



MISCELLANEOUS

*Below are photos of great examples of ADA compliance.



