

EXISTING FACILITIES

MILAN CITY PARK - Milan, TN

PARKING

There is various accessible parking across the park and its activity locations. Not all had marked aisles.

Note that none of the parking spots are labeled “van accessible”.



PLAY AREAS

Not all play areas are accessible by a path, and not all have accessible routes to vertical components of the area. The park does provide Spirit's Playground, which is fully accessible.



AMPHITHEATER

The access ramp on the backside of the stage is steep with no railing.



TOILET ROOMS

Only one set of restrooms in the park are labeled as handicap accessible and are located at the Lyons Pavilion near the entrance of the park.

Signage is positioned correctly and the letters are contrast with the background but there is no braille.



The lock cannot be used without pinching or twisting.



There is not at least 12 inches of clearance above the grab bar.

Also, note that the flush control is not on the open side of the compartment.



There is no insulation or cover over pipes to prevent contact.

Also, note obstruction under women's sink.



CONTROLS

The light switch in the Lyons pavilion is too high.




POOL

At the time of the assessment, the pool was closed for season. It does not appear to have a slope entry or a lift into the pool or a transfer system. But accessible steps did appear to be present but without rails on both sides of the steps.



SPORTS AREAS

The park has various sports areas for sports including baseball, softball, soccer, tennis, and more. Some playing areas were accessible including the tennis court, but most were not easily accessible. Also, bleachers were not consistently accessible for spectators. Below are pictures of examples.







DRINKING FOUNTAIN

I only recall seeing one drinking fountain and it was located off the accessible trail.



TRAIL ACCESS

The park had several accessible points to the walking trail and marked well. The photo below is an access point that is marked but has a lip at the transition.

